

COMPRESSOR DATA SHEET

Rotary Screw Compressor

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: CompAir	7/5/06	
2	Model Number: L15 <input checked="" type="checkbox"/> Air-cooled <input type="checkbox"/> Water-cooled <input checked="" type="checkbox"/> Oil-injected <input type="checkbox"/> Oil-free	# of Stages: 1	VALUE UNIT
3	Rated Capacity at Full Load Operating Pressure ^{a, f}	82	acfm ^{a, f}
4	Full Load Operating Pressure ^b	100	psig ^b
5	Maximum Full Flow Operating Pressure ^c	109	psig ^c
6	Drive Motor Nameplate Rating	20	hp
7	Drive Motor Nameplate Nominal Efficiency	90.2	percent
8	Fan Motor Nameplate Rating (if applicable)		hp
9	Fan Motor Nameplate Nominal Efficiency		percent
10	Total Package Input Power at Zero Flow ^e	6.0	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	16.41	kW ^d
12	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure ^g	20.1	kW/100 cfm ^g

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with the CAGI/PNEUROPEAN PN2CPTC2 Test Code (Annex C to ISO 1217). ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in the CAGI/PNEUROPEAN PN2CPTC2 Test Code (Annex C to ISO 1217).
- f, g. Tolerance is specified in the CAGI/PNEUROPEAN PN2CPTC2 Test Code (Annex C to ISO 1217) as follows:



Volume Flow Rate at specified conditions		Volume Flow Rate ^f	Specific Energy Consumption ^g
<u>m³ / min</u>	<u>ft³ / min</u>	%	%
Below 0.5	Below 15	+/- 7	+/- 8
0.5 to 1.5	15 to 50	+/- 6	+/- 7
1.5 to 15	50 to 500	+/- 5	+/- 6
Above 15	Above 500	+/- 4	+/- 5

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.